

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0026:270 Page 1 of 1

CATEGORY: Control Unit (Non-High Rise)

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542

DESIGN: Model AUTOCOMMAND II (ACII) Automatic or manual; local, auxiliary, proprietary service; waterflow and sprinkler supervision. Electrical rating 120 Vac. System components:

7155-040	5200-462-001	5200-462-002
5200-440	5200-466	5200-422
5130-074-15	5200-410	5130-107-09
5130-074-03	5200-460	5130-091-12
5130-091-11	5130-105-23	3150-100-84
5130-105-29	3150-057	3132-033
5200-409	5200-458	D5290-013
D5200-214	D5200-437	4283-021
4284-060	4284-061	330-F2-22L
330-16R-16	RA110671	

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7165-0077:108, 7165-1493:115

06-21-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager